

May 7, 2024

Mr. Kevin Piel Fox C-6 School District 745 Jeffco Boulevard Arnold, MO 63010

RE: Drinking Water Sampling – Bus Garage

3845 Old State Rd M, Imperial, MO 63052

Project Number: 923294

Mr. Kevin Piel,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at the bus garage in Imperial, Missouri. The sampling was requested and approved by Mr. Kevin Piel of Fox School District (FSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the "Get the Lead Out of School Drinking Water Act".

#### **METHODOLOGY**

On March 28<sup>th</sup>, 2024, Mr. Justin Arnold of OCCU-TEC completed testing of three (3) sources throughout the bus garage. Samples were collected as 'First Draw' samples after the fixtures had remained unused for a minimum period of 8 hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers. Sample location information and photographic documentation are noted in the attached table.

Samples were shipped to Teklab, Inc. (Teklab) of Collinsville, Illinois for analysis using EPA method 200.8. Teklab is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification number 00930. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

#### **RESULTS**

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, zero (0) of the three (3) contained lead concentrations at or above 5 ppb.

Sample ID	Location	Туре	Result (ug/L)							
No samples collected contained results above 5 ug/L (ppb)										

#### LIMITATIONS

At the request of FSD, custodial closet sinks were excluded from sampling. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water.

#### **RECOMMENDATIONS**

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random "Flush" sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

### SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to FSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,

Kevin Heriford Director EH&S Dept. Brittany Dickmeyer Safety Specialist

#### **ATTACHMENTS**

Outlet Inventory with Analytical Results Summary Laboratory Analytical Results and COC Documentation

# Drinking Water Assessment Bus Garage Fox C-6 School District

ID:	294	4-BG-01	Location:	Lobby/	Break Area							
Photo:			Manufacturer:	E	Ikay							
			Description:									
			Drinking Founta	in Bubbler								
			Result: <1.0 ppb									
			Date Sampled:	3/28/2024	By: JEA							
Recommen	nded Action:											

ID:	29-	4-BG-02	Location:	Men's	Restroom								
Photo:			Manufacturer:	Manufacturer: Chicago Faucet									
				Description:									
			Handwashing S	iink									
			Result:	<1.0	ppb								
			Date Sampled:	3/28/2024	By: JEA								
Recomme	nded Action:												

ID:	29	4-BG-03	Location:	Women	's Restroom
Photo:			Manufacturer:	ucet Company	
				Description:	
			Handwashing S	ink	
			Result:	2.9	ppb
			Date Sampled:	3/28/2024	By: JEA
Recommen	ded Action:				



April 24, 2024

Justin Arnold Occu-Tec 2604 NE Industrial Drive Suite 230 North Kansas City, MO 64117

TEL: (816) 810-3276

FAX:



 Illinois
 100226

 Illinois
 1004652024-2

 Kansas
 E-10374

 Louisiana
 05002

05003

Oklahoma 9978

Louisiana

**RE:** 923294 BG **WorkOrder:** 24032338

Dear Justin Arnold:

TEKLAB, INC received 3 samples on 3/28/2024 10:30:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Patrick Riley
Project Manager

(618)344-1004 ex 44

patrickriley@teklabinc.com



# **Report Contents**

http://www.teklabinc.com/

Client: Occu-Tec Work Order: 24032338
Client Project: 923294 BG Report Date: 24-Apr-24

#### This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended



#### **Definitions**

http://www.teklabinc.com/

Report Date: 24-Apr-24

Client: Occu-Tec Work Order: 24032338 Client Project: 923294 BG

#### Abbr Definition

- \* Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
  - DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
  - DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- **NELAP NELAP Accredited** 
  - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
  - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
  - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
  - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
  - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
  - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count ( > 200 CFU )



# **Definitions**

http://www.teklabinc.com/

Client: Occu-Tec Work Order: 24032338
Client Project: 923294 BG Report Date: 24-Apr-24

#### **Qualifiers**

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
  - S Spike Recovery outside recovery limits
  - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



# **Case Narrative**

http://www.teklabinc.com/

Work Order: 24032338

Report Date: 24-Apr-24

Client: Occu-Tec Wo
Client Project: 923294 BG Rej

Cooler Receipt Temp: N/A °C

#### Locations

	Collinsville		Springfield	Kansas City					
Address	5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road				
	Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214				
Phone	(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998				
Fax	(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998				
Email	jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com				
	Collinsville Air		Chicago						
Address	5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.						
	Collinsville, IL 62234-7425		Downers Grove, IL 60515						
Phone	(618) 344-1004	Phone	(630) 324-6855						
Fax	(618) 344-1005	Fax							
Email	EHurley@teklabinc.com	Email	arenner@teklabinc.com						



# **Accreditations**

# http://www.teklabinc.com/

Work Order: 24032338 Client: Occu-Tec Client Project: 923294 BG

Report Date: 24-Apr-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2025	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



# **Laboratory Results**

#### http://www.teklabinc.com/

Client: Occu-Tec Work Order: 24032338
Client Project: 923294 BG Report Date: 24-Apr-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.	4, 200.8 R5.4, META	LS BY ICPMS (TOTAL)	)					
Lead								
24032338-00	IA 293-BG-01	NELAP	1.0	< 1.0	μg/L	1	04/23/2024 8:47	03/28/2024 10:21
24032338-002	2A 293-BG-02	NELAP	1.0	< 1.0	μg/L	1	04/23/2024 8:51	03/28/2024 10:22
24032338-003	BA 293-BG-03	NELAP	1.0	2.9	μg/L	1	04/23/2024 8:55	03/28/2024 10:23



# **Receiving Check List**

http://www.teklabinc.com/

Work Order: 24032338 Client: Occu-Tec Client Project: 923294 BG Report Date: 24-Apr-24

Carrier: Craig McKinney

Amber Dilallo

Completed by:

On:

28-Mar-24

OMOON DISCULC

Reviewed by: On:

Received By: LM

01-Apr-24

Elizabeth A. Hurley

Elizabeth a Hurley

Extra pages included 0 Pages to follow: Chain of custody Shipping container/cooler in good condition? **✓** No 🗔 Not Present Temp °C N/A Type of thermal preservation? **~** Ice \_ Blue Ice None Dry Ice Chain of custody present? **~** No L Yes Chain of custody signed when relinquished and received? **~** Yes No L **~** Chain of custody agrees with sample labels? No 🗀 Yes **~** No 🗌 Samples in proper container/bottle? Yes **V** No 🗌 Sample containers intact? Yes Yes **~** No Sufficient sample volume for indicated test? **~** No  $\square$ All samples received within holding time? Yes NA 🗸 Field Lab  $\square$ Reported field parameters measured: Yes 🗸 No 🗌 Container/Temp Blank temperature in compliance? When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected. No VOA vials 🗸 Water - at least one vial per sample has zero headspace? Yes 🗌 No 🗀 No TOX containers Water - TOX containers have zero headspace? Yes No 🗌 Yes 🗹 No 🗌 Water - pH acceptable upon receipt? NA 🗸 NPDES/CWA TCN interferences checked/treated in the field? Yes No 🗀 Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

## **Print PDF**

# **CHAIN OF CUSTODY**

Pg of Workorder # 2403233 8

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: OCCU-TEC Inc,				Sa	mple	s on	1:		CE	=		BLU	JE IC	Έ	X	NO I	CE	$D_i$	4	°C												
	ndustrial Drive Suite 230				Pre	esen	ved i	n:	X	LAE	3		FEL	D		FC	OR L	AB U	SE Ĉ	NLY	, -											
City/State/Zip: North Kansas City, MO 64117				·	LA	B NO	OTES	<b>S</b> :	/	\								á	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	P.												
Contact: Justin Arnol	ld	Phone: 816	-810-3276		L										£:000******			Sc.	Ž.,													
Email: jarnold@oc	cutec.com	Fax: 816-9	94-3478		Client Comments:																											
				ease provide			<5.0											*														
PROJECT NAME/N	UMBER	SAMPLE COL	LECTOR'S	SNAME	#	and	і Ту	pe c	of C	onta	ine	rs		INDI	CAT	EA	NAL	YSIS	RE	QUE	STE	ED										
923294		Justin Arnold											_							-												
RE	SULTS REQUESTED		BILLIN	G INSTRUCTIONS	]_	ェ	z	٠Į:	_   =	NaHSO4		Q	Lead by 200.8																			
✓ Standard	1-2 Day (100% S	urcharge)	·	:	UNP P	ő	후	우	후	후	후	오	오	후	皇	운양	NaOH			S	TSP	Other	y 20								DEPATTMENT	
Other	3 Day (50% Surc	harge)			1		]	_		4			0.8								***************************************											
Lab Use Only	Sample ID	Date/Time	Sampled	Matrix	Ļ	<u> </u>		4	_	<u> </u>			_	<del> </del>			_	<u> </u>	_	-	_											
24032335	293-BG- ॔ (	3/28/2024 - {	021	Drinking Water	×			4	<u> </u>		ــــــــــــــــــــــــــــــــــــــ	Ш	<u> </u>	_				igspace			4	<del>                                     </del>										
07	293-BG- 0 と	3/28/2024 - {	022	Drinking Water	Х	Ш		_	$\perp$	$\bot$	<u> </u>		<b>√</b>		<u> </u>	$\perp$						1-										
~33	293-BG- 03			Drinking Water	Х				_	$\bot$	<u> </u>		<b>√</b>					<u> </u>		_	_											
	293-BG-	3/28/2024 -	023	Drinking Water	X			$\bot$			_		✓		<u> </u>			_			<u> </u>	<u> </u>										
	293-BG-	3/28/2024 -		Drinking Water	Х						ऻ		$\checkmark$																			
	293-BG-	3/28/2024 -		Drinking Water	Х								<b>√</b>																			
	293-BG-	3/28/2024 -		Drinking Water	X								<b>√</b>																			
	293-BG-	3/28/2024 -		Drinking Water	Х								✓					ALL PARTY PORTS		$\perp$												
	293-BG-	3/28/2024 -		Drinking Water	Х								✓																			
	293-BG-	3/28/2024 -		Drinking Water	Х						_		/							$\bot$	Ŧ											
	293-BG-	3/28/2024 -		Drinking Water	Х				1	)			√		L,		_		$oxed{oxed}$													
1	Relinquished By			Date/Time	╄	<del></del>	_	-		Rec	eive	ed E	у			<i>,</i>		<del>-</del> /		<del>. /</del>	ime	·····										
Clargo 148		del p	128/24 7:00	╀	<del></del>		$\leq$									ē	-	1	2		<u> </u>											
		12	8/24 1000	╀				V	1/	<u> </u>						+	3/2	8/6		_/\	<u> </u>											
				:	-												+															
					$\dagger$						····						$\dashv$															
•			I									_			A	8					_											

<sup>\*</sup>The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions